



January 28, 2009

Mr. Lester Hensley
Emseal Joint Systems Ltd.
25 Bridle Lane
Westborough, MA 01581-2603

Re: Joint System EMSHIELD DFR2
File No. 26111
Project No. 08CA51790

EMSEAL product named "EMSHIELD DFR2", was tested in accordance with UL2079 standard, Tests for Fire Resistance of Building Joint System, 4th edition dated October 21, 2004. The product was evaluated to the seismic cycle rate, (class III movement capability), and then fire tested for a period of 2 hours. The product met the requirements of UL2079 for the above conditions.

We are in the process of finalizing our report pertinent to this test process, after which EMSEAL will be permitted to apply for the UL Mark under their Follow-up Service Agreement.

Classification Mark of Underwriters Laboratories Inc. on the product is the only method provided by UL to identify products manufactured under its Classification and Follow-Up Service.

“Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized Licensee of UL”

Regards,

Claude Travers, P Eng
Project Engineer
Fire Protection Division
Underwriters Laboratories Inc

Abbas Nanji, P Eng
Engineering Group Manager
Fire Protection Division
Underwriters Laboratories Inc